




WORKSHEET

- ASME Dataplate present and legible.
- ASME Dataplate NOT present or legible.

Use this worksheet to document NTIP tests/inspections for anhydrous ammonia vessels. (Does not include trailers/running gears.)

1. ORIGIN INFORMATION (OPTIONAL)		2. NTIP NUMBER	
SERIAL NO.: _____			
MANUFACTURER: _____			
DATE MANUFACTURED: _____			
3. CAPACITY (Gallons as Calculated)	4. TANK IDENTIFICATION		
5. OWNER	6. FACILITY NO.	8. ADDRESS (No PO Boxes)	9. CITY
10. STATE		11. ZIP CODE	

12. EXTERNAL VISUAL (V)			13. THICKNESS (T)		14. PRESSURE (RETEST) (P)		
PASS	FAIL	CHECKLIST-INSPECTED/TESTED	HEAD THICKNESS TEST POINTS:		A. FLUID USED FOR TEST (HYDROSTATIC ONLY)		
		a. Tank Shell	FRONT	REAR	WATER: <input type="checkbox"/> YES <input type="checkbox"/> NO		
		b. Tank Heads	(A) _____	_____	B. TEST PRESSURE (MINIMUM: 375 _____) Refer to _____		
		c. Head-to-Shell Seam	(B) _____	_____	psig: _____ Instructions for _____		
		d. Valves	(C) _____	_____	C. HOLDING TIME OF TEST (MINIMUM: 10 MINUTES)		
		e. Piping	(D) _____	_____	STATE: _____		
		f. Suspension System Attachments	(E) _____	_____	D. GASKETS		
		g. Connecting Structures	LIQUID LEVEL LINE TEST POINTS:		INSPECTED/TESTED		
		h. Corroded/Abraded Areas	LEFT	RIGHT	E. EXCESSIVE RELIEF VALVES		
		i. Distortions	(F) _____	_____	<input type="checkbox"/> Old <input type="checkbox"/> New		
		j. Dents	(G) _____	_____	20. INSPECTION PERFORMED AT OWNERS ADDRESS? <input type="checkbox"/> YES		
		k. Welds	(H) _____	_____	IF NO, PROVIDE ADDRESS: _____		
		l. Nuts & Bolts	ARC WELDING TEST POINTS:		21. (MUST CHECK ONE)		
		m. Placards	LEFT	RIGHT	TANK: <input type="checkbox"/> MEETS <input type="checkbox"/> FAILS TO MEET		
		n. Piping	(I) _____	_____	THE DOT INSPECTION/TEST REQUIREMENTS.		
		o. Other	(J) _____	_____	Remarks: _____		
		p. Other	(K) _____	_____	22. (MUST CHECK ONE) THIS TANK HAS BEEN WITHDRAWN		
		q. Other	(L) _____	_____	FROM SERVICE. <input type="checkbox"/> YES <input type="checkbox"/> NO		
		r. Other	(M) _____	_____	23. DOT REGISTRATION NUMBER OF TESTING FACILITY		
		s. Other	FIELD TEST POINTS:		PERSON		
		t. Other	BOTTOM	TOP:	"CT" NO: _____		
		u. Other	(P) _____	(U) _____	25. INSPECTED/TESTED BY (Print Person's Name)		
		v. Other	(Q) _____	(V) _____	26. Date		
		w. Other	(R) _____	_____	NOTICE		
		x. Other	(S) _____	_____	To complete the NTIP inspection/test process, go to		
		y. Other	(T) _____	_____	www.asmark.org then click on NTIP, logon and enter		
		z. Other	SIDE KEY		the information from this worksheet into the website.		
		aa. Other	U	I	J	K	
		ab. Other	N	F	G	H	
		ac. Other	P	Q	R	S	
		ad. Other	M	O	T		
		ae. Other	MINIMUM THICKNESS:				
		af. Other	• 1,500 gallon vessels or more = 0.25				
		ag. Other	• <1,500 gallon = 0.203(head) 0.239(shell)				



Note: More information on back.

© 2012 NTIP

The inspection/test results documented on this Worksheet must be entered into the NTIP website to obtain an official NTIP Inspection Report.



WORKSHEET ADDENDUM

Use this worksheet to document NTIP tests/inspections for anhydrous ammonia vessels. (Does not include trailers/running gears.)

29. TANK ORIGIN INFORMATION

PROVIDE THE FOLLOWING IF AVAILABLE: N/A
MANUFACTURER: _____
DATE MANUFACTURED: _____
SERIAL NO: _____
DOT SPECIFICATION NUMBER: _____
MAWP in psig: _____

30. TANK INFORMATION

(CHECK ALL THAT APPLY)

- Lined
- Insulated
- Dedicated Service: _____
- Special Service
- Other: _____

Comments:

31. INFORMATION ON ANY DEFECTS/DAMAGE

(MUST CHECK ONE) NO DEFECT OR DAMAGE DISCOVERED DEFECT(S) OR DAMAGE DISCOVERED

Location of Defect(s) or Damage:

Nature and Severity:

Method of Repairs: REPAIR CERTIFICATION REQUIRED REPAIR CERTIFICATION **NOT** REQUIRED

If YES, Certification/Registration No: _____

Post Repair Determination: Tank: MEETS FAILS TO MEET The DOT Inspection/Test Requirements

32. INFORMATION ON REPAIRING FACILITY

REPAIRED BY (Company)	REPAIRED BY (Person)	REPAIR DATE
ADDRESS	ASME or National Board Number of Repair Facility	MARKINGS APPLIED

NOTICE

To complete the NTIP inspection/test process, go to www.asmark.org then click on NTIP, logon and enter the information from this worksheet into the website. Print, sign and distribute a copy of the official NTIP Inspection Report to the CT inspector and the owner of the tank.

Note: More information on front.

© 2012 NTIP

The inspection/test results documented on this Worksheet must be entered into the NTIP website to obtain an official NTIP Inspection Report.

Nurse Tank Inspection Report Instructions

Locate the Worksheet provided in each NTIP Inspection Kit and record the data from your test/inspections using the following instructions.

Insert an "X" in the appropriate box indicating whether the tank has an ASME dataplate present and legible or whether the ASME dataplate is NOT present or legible.

Following numbers correspond to each box on the Nurse Tank Inspection Report form and the NTIP Worksheet.

1. ORIGIN INFORMATION

Insert the following information as applicable.

a. Serial Number

Insert the serial number from the ASME dataplate, if legible.

b. Manufacturer

Insert the name of the manufacturer from the ASME dataplate, if legible.

c. Date Manufactured

Insert the date manufactured from the ASME dataplate, if legible.

2. NTIP NUMBER

Record the NTIP number on the tank being tested/inspected. This number will be used to verify and track the inspection history related to each individual tank. Accuracy is very important.

- For tanks previously inspected under NTIP, record the previous NTIP number from the decal on the tank.
- For tanks being inspected for the first time, record the NTIP number from the decal provided in the kit.

3. CAPACITY

This is the total number of gallons (water) the tank has the capacity to contain. This number should be confirmed and based on the dimensions of the tank.

Typical tank dimensions and relative capacity: (for information only)

Capacity (Water Gallons)	Diameter	Length
1,000	41"	16'-0"
1,450	46"	17'-4"
2,000	46"	24'-1"

Formula for calculating tank capacities:

For a cylinder:

$$ID^2 \text{ (inches)} \times .0034 \times \text{length of cylinder (inches)} = \text{gallons (water)}$$

For two elliptical heads:

$$ID^3 \text{ (inches)} \times .001133 = \text{gallons (water)}$$

For two hemispherical (half globe) heads:

$$ID^3 \text{ (inches)} \times .002266 = \text{gallons (water)}$$

Assumptions:

$$7.48 \text{ gallons} = 1 \text{ Cubic Foot}$$

$$1 \text{ Gallon water} = 8.3453 \text{ Pounds}$$

ID - Inside Dimension

4. TANK IDENTIFICATION

Insert the identification number that is assigned to each respective tank by the facility. This is an internal number used by each company to identify their tanks.

5. OWNER

Insert the name of the company/individual that owns the tank to be tested.

6. FACILITY NUMBER

Insert the number of the facility to which the tank being tested is based. This is an optional number and may not apply. The facility number (may also be referred to as a unit number) is applicable to companies with several locations and each location has been assigned a facility number by their company.

7. OWNER SIGNATURE

Insert the signature of the operator of the facility on the Official NTIP Inspection Report. The Official NTIP Inspection Report is produced after the results are entered into the website.

8. ADDRESS

Insert the street address of the facility to which the tank being tested is based. This address must be a physical street address and not a P.O. Box address.

9. CITY

Insert the city of the facility to which the tank being tested is based. This city will refer to the physical street address of the facility and not a P.O. Box address.

10. STATE

Insert the state applicable to the address for the facility where the tank being tested is physically based.

11. ZIP CODE

Insert the zip code applicable to the address for the facility where the tank being tested is physically based.

12. EXTERNAL VISUAL (V)

Insert an "X" in the appropriate box indicating whether the tank has passed or failed the visual inspection based on the criteria listed below:

a. Tank Shell

Visually inspect the tank shell to ensure the tank welds are in good condition and to identify any bulges, cracks, dents, gouges, corrosion or abrasion.

b. Tank Heads

Visually inspect the tank heads to ensure the welds are in good condition.

c. Head-to-Shell Seam

Visually inspect the head-to-shell seam to ensure the welds are in good condition.

d. Valves

Visually inspect valves by checking for any thread deterioration. With the tank bled off and pressure released, operate the valve to detect difficulties in movement, deteriorated packing or worn seats. Check the gasket, handle, dust cap, plug and pressure bleed off for their condition, leakage, distortion and corrosion.

e. Piping

Visually inspect all piping for cracks or signs of leakage. The piping should also be inspected visually for thread deterioration, corrosion, signs of vibration, and distortion. Look at each pipe to verify it is properly supported.

f. Suspension System Attachments

Visually inspect the suspension of the nurse tank to verify all bolts are present, tight and properly secured to the running gear, the legs are in good condition with no cracks or elongated holes, the springs, if any, are in good condition.

g. Connecting Structures

Visually inspect connecting structures to ensure they are in good condition. The inspection should verify that welds are in good condition, cracks are not present, there is not distortion or deformation of the structures, and bolts are present and tight.

h. Corroded/Abraded Areas

Visually inspect the tank for corroded and scraped areas. The pass/fail determination should be based on whether the identified areas compromise the integrity of the tank.

i. Distortions

Visually inspect the tank for distortions. The pass/fail determination should be based on whether the identified areas compromise the integrity of the tank.

j. Dents

Visually inspect the tank for dents. For dents at welds or that include a weld, the maximum allowable depth is 1/2 inch. For dents away from welds, the maximum allowable depth is 1/10 of the greatest dimension of the dent, but in no case may the depth exceed one inch. (180.411)

k. Welds

Visually inspect welds to ensure they are in good condition and do not compromise the integrity of the tank.

l. Nuts & Bolts

Visually inspect the bolts to ensure they are present, tight with no cracks or elongated holes.

m. Markings

See attached information for proper markings and visually inspect the tank to ensure it is marked accordingly.

n. Paint

Visually inspect the paint to ensure the tank is properly protected from corrosion.

o. Other

Visually inspect the tank for any other identified deficiencies not previously identified that could compromise the integrity of the tank and list them here.

p. Other

Visually inspect the tank for any other identified deficiencies not previously identified that could compromise the integrity of the tank and list them here.

13. THICKNESS (T)

Test the thickness of the tank at the points specified below and record them on the appropriate line of the form.

Head Thickness Test Points (Test Points A-E)

Use a testing device to determine the thickness of the front and rear heads of the tank at each point designated on the "end key" diagram of the form and record them beside each corresponding letter. The thickness of these head points must be at least .203" for tanks less than 1,500 gallon capacity and .25" for tanks equal to or greater than 1,500 gallon capacity.

Liquid Level Line Test Points (Test Points F-H)

Use a testing device to determine the thickness of the liquid level line test points as designated on the "side key" diagram of the form and record them beside each corresponding letter. The thickness of these liquid level test points must be at least .239" for tanks less than 1,500 gallon capacity and .25" for tanks equal to or greater than 1,500 gallon capacity.

Around Openings (Test Points I-M)

Use a testing device to determine the thickness around openings as designated on the "side key" diagram of the form and record them beside each corresponding letter. The thickness of these liquid level test points must be at least .239" for tanks less than 1,500 gallon capacity and .25" for tanks equal to or greater than 1,500 gallon capacity.

Weld Joint Test Points (Test Points N-V)

Use a testing device to determine the thickness of the weld joint test points on the sides, top and bottom of the tank as designated on the "side key" diagram of the form and record them beside each corresponding letter. The thickness of these liquid level test points must be at least .239" for tanks less than 1,500 gallon capacity and .25" for tanks equal to or greater than 1,500 gallon capacity.

14. PRESSURE (RETEST) (P)**A. Fluid Used For Test (Hydrostatic Only)**

Verify that water was used for the pressure test by checking the box for "Yes." Follow the pressure test procedures found in 180.407(g) which includes (ii) removing the relief valves, and (vii) which requires all closures except pressure relief devices to be kept in place during the test.

B. Test Pressure (Minimum: 375 psig)

Ensure the tank pressure is at zero and empty. Fill the tank with water and pressurize the tank to test pressure (1.5 times the maximum working pressure). If the tank has a maximum working pressure of 250 psig, the test pressure should be 375 psig. Some states require tanks with a maximum working pressure of 265 psig. In that situation, the maximum test pressure should be 397.5 psig (265 x 1.5). Record the maximum test pressure used in the space provided on the form.

C. Holding Time Of Test (Minimum 10 Minutes)

Record the amount of time the maximum pressure was maintained. This must be completed by recording the start time and stop time on the form in the space provided. This time should be a minimum of 10 minutes.

D. Gaskets

Indicate with an "X" in the "Pass" or "Fail" box whether the gaskets have been inspected and meet requirements.

E. Excess Flow Valves

Indicate with an "X" in the "Pass" or "Fail" box whether the excess flow valves have been inspected and meet requirements. It is not a DOT requirement to test the excess flow valve, however, it is recommended. The excess flow valves must be in place during the pressure test. The recommended procedure is to test to see that the excess flow valve works properly to stop the flow. It is recommended that new excess flow valves be tested immediately after being installed.

F. Re-closing Pressure Relief Valves

Indicate with an "X" in the "Pass" or "Fail" box whether the pressure relief valve has been inspected and meets requirements. The inspector must also indicate by placing an "X" in the appropriate box as to whether the pressure relief valve is new or been tested.

- 15. REPAIRS (IF ANY) MADE BY:**
Record the name of the person who made any repairs on the tank identified during the inspection.
- 16. DATE**
Record the date of any repairs made on the tank identified during the inspection.
- 17. ADDRESS**
Record the physical street address of the person who made any repairs on the tank identified during the inspection.
- 18. CITY, STATE, ZIP CODE**
Record the city, state and zip code for the address of the person who made repairs on the tank identified during the inspection. The city, state and zip code in this box should correspond to the street address listed in box #17.
- 19. (CHECK AS APPROPRIATE)**
Enter an "X" in the appropriate box whether the defects identified previously have been corrected or if the defects identified previously need not be corrected. Enter the initials of the inspector and provide any remarks related to the correction of defects.
- 20. INSPECTION PERFORMED AT OWNERS ADDRESS**
Indicate the inspection was performed at the owners address as listed in box #8 above by placing an "X" in the box next to "Yes." If the inspection was performed at an address other than the one listed in box #8 above, provide the address on the form where the inspection was performed.
- 21. TANK "MEETS" OR "FAILS TO MEET" TEST REQUIREMENTS**
Enter an "X" indicating whether the tank "meets" or "fails to meet" the DOT inspection/test requirements. The inspector may also enter any remarks that are relevant to the inspection in the space provided.
- 22. THIS TANK HAS BEEN WITHDRAWN FROM SERVICE**
Enter an "X" in the appropriate box indicating if this tank has been withdrawn from service.
- 23. DOT REGISTRATION NUMBER OF TESTING FACILITY PERSON**
Enter the "CT" number of the person who is listed as a registered inspector with DOT to conduct inspections.
- 24. INSPECTOR/TESTED BY**
The registered inspector must sign their name in this box on the Official NTIP Inspection Report. The Official NTIP Inspection Report is produced after the results are entered into the website.
- 25. INSPECTOR/TESTED BY**
The registered inspector must print their name in this box.
- 26. DATE**
Enter the date the inspection was conducted.
- 27. ADDRESS**
Enter the physical street address for the registered inspector on the Official NTIP Inspection Report. The Official NTIP Inspection Report is produced after the results are entered into the website.
- 28. CITY, STATE, ZIP CODE**
Enter the city, state and zip code of the registered inspector which corresponds to the street address entered in box #27 on the Official NTIP Inspection Report. The Official NTIP Inspection Report is produced after the results are entered into the website.

29. TANK ORIGIN INFORMATION

This section pertains to a nurse tank with an illegible or missing ASME dataplate. For tanks missing the dataplate, indicate by marking an "X" in the Not Applicable (N/A) box. For tanks with an illegible dataplate, record any/all legible information required on the form.

30. TANK INFORMATION

Indicate with an "X" in the "Dedicated Service" box the nurse tank is dedicated to use with anhydrous ammonia. (All tanks must be dedicated to anhydrous ammonia service if included in NTIP.)

31. INFORMATION ON ANY DEFECTS/DAMAGE

Indicate with an "X" in the appropriate box whether defects/damage was discovered. Information pertaining to any defects or damage should be listed in the appropriate section of the NTIP Inspection Report. If defects or damage were discovered, the CT may note on the NTIP Addendum to refer to the NTIP Inspection Report or use this section to provide any additional information.

Indicate with an "X" in the appropriate boxes the information pertaining to "Method of Repairs" and "Post-Repair Determination."

Reminder: Repairs involving welding on a nurse tank with a missing or illegible ASME dataplate are prohibited by DOT.

32. INFORMATION ON REPAIRING FACILITY

Repairs involving welding on a nurse tank with a missing or illegible ASME dataplate are prohibited by DOT; therefore it is unlikely this section would be completed. In the event a DOT-allowed repair to the nurse tank is made, complete this section with the required information.



Notice:

To complete the NTIP inspection/test process, go to www.asmark.org, then click on NTIP, logon and enter the information from this Worksheet into the website. This will produce the official NTIP Inspection Report. Print, sign and distribute a copy of the official NTIP Inspection Report to the CT Inspector and the owner of the tank.

Ammonia Tank Markings

Marking	Example	Storage Tank	Nurse Tank	Applicator Tank
NFPA Diamond	A	Locate decals to be seen by emergency responders.	N/A	N/A
Slow Moving Vehicle (SMV)	B	N/A	One decal on the rear of wagon.	One decal on the rear of the applicator.
Health & Physical Hazards	C	One decal located near the primary transfer point.	One decal located near the primary transfer point.	One decal located near the primary transfer point.
"Inhalation Hazard"	D	N/A	Two decals with 2" letters (minimum) on opposite sides.	Two decals with 2" letters (minimum) on opposite sides.
"Anhydrous Ammonia"	E	N/A	Four decals with 2" letters (minimum) on all four sides.	Four decals with 2" letters (minimum) on all four sides.
First Aid Information	F	One decal located in a visible location.	One decal located near the primary transfer point.	One decal located near the primary transfer point.
"1005" D.O.T. Placard	G	N/A	Four decals with one affixed to each side.	Four decals with one affixed to each side.
"Caution Ammonia"	H	Two decals with 4" letters (minimum) on opposite sides.	N/A	N/A
Transfer Instructions	I	N/A	N/A	One decal located near the primary transfer point.
"Gloves & Goggles Required"	J	One decal located near the primary transfer point.	N/A	N/A
Confined Space	K	One decal located near the manhole.	N/A	N/A
NTIP Decal(s) (Nurse Tank Inspection Program) -First-time -Re-Inspection	L	N/A	One decal located near the primary transfer point.	One decal located near the primary transfer point.

ALWAYS CONSULT YOUR STATE AGENCIES FOR ADDITIONAL REQUIREMENTS






C

**Health
and
Physical
Hazards**

D

Inhalation Hazard



H

**CAUTION

AMMONIA**

I

TRANSFER INSTRUCTIONS

- 1. Safety Precautions:**
 - 1.1. Before starting work, the operator must read the instructions on the label and the instructions on the label.
 - 1.2. The operator must wear the appropriate personal protective equipment (PPE) as indicated on the label.
 - 1.3. The operator must ensure that the cargo tank is properly secured and that the transfer process is controlled.
- 2. Pre-Work Application Check:**
 - 2.1. The operator must ensure that the cargo tank is properly secured and that the transfer process is controlled.
 - 2.2. The operator must ensure that the cargo tank is properly secured and that the transfer process is controlled.
- 3. Transfer Instructions:**
 - 3.1. The operator must ensure that the cargo tank is properly secured and that the transfer process is controlled.
 - 3.2. The operator must ensure that the cargo tank is properly secured and that the transfer process is controlled.

APPLICATION INSTRUCTIONS

- 1. Application Instructions:**
 - 1.1. The operator must ensure that the cargo tank is properly secured and that the transfer process is controlled.
 - 1.2. The operator must ensure that the cargo tank is properly secured and that the transfer process is controlled.

J

CAUTION
GLOVES & GOGGLES
REQUIRED WHEN
TRANSFERRING

K

DANGER
CONFINED SPACE
ENTER BY
PERMIT ONLY

L

NTIP No: 100001
CARGO TANK INSPECTION

THIS CARGO TANK HAS SUCCESSFULLY
COMPLETED THE TEST AND INSPECTED
REQUIREMENTS CONTAINED IN 180.407

- - -V,T,P

(Example of First-Time)